



Single Plane 4 Run Balancing

Date and Time: Jun 21, 2021 14:13:53 PM Staff Name: John Smith
 Machine: Machine 1 Plant: Austin

Rotor Weight: 2.00 Kg
 Rotor Speed: 2400.0000 RPM
Original Vibration: 0.8482
 Trial Weight: 0.53 gr
 Trial Weight Radius: 15.00 mm
 Correction Weight: 0.14 gr
 Correction Weight Radius: 15.00 mm
 Correction Weight Angle: 322°
Vibration with Correction Weight: 0.0752



Notes
 Note



Jun 21, 2021 14:15:05 PM

